



**ADDENDUM  
PURCHASING OFFICE  
CITY OF AUSTIN, TEXAS**

---

**Solicitation: IFB 2200 PAT1034**

**Addendum No: 2**

**Date of Addendum: June 15, 2020**

---

This addendum is to incorporate the following changes to the above referenced solicitation:

**I. Document Changes:**

1. The Pre-Offer Meeting Sign-In Sheet is attached.

**II. Questions:**

(Q1) Does this Solicitation include Bid Bonds?

(A1) No, this Solicitation does not include any Bid Bonds?

(Q2) What is the electrical National Electric Code (NEC)/International Electrotechnical Commission (IEC) hazardous area classification of the location where the new equipment will be installed?

(A2) The location where the new equipment will be installed is considered an Unclassified area by Austin Water, thus, explosion-proof rated equipment is not required. However, specific equipment types such as TEFC, ODP, or TEACC for motors, or electrical ratings such as NEMA, UL, IP, etc. for enclosures, instruments or other electrical-related equipment are required and those requirements are provided in the 0500 Purchase Specification.

(Q3) Is this a hydro-blasting job or is the City changing out this equipment?

(A3) The Solicitation will be for new equipment that will replace aging equipment that is currently in place.

APPROVED BY: \_\_\_\_\_  
Paul Trimble, Procurement Specialist II  
Purchasing Office, 512-974-1714

\_\_\_\_\_  
Date

ACKNOWLEDGED BY:

\_\_\_\_\_  
Name

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date

**RETURN ONE COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE, CITY OF AUSTIN, WITH YOUR RESPONSE OR PRIOR TO THE SOLICITATION CLOSING DATE. FAILURE TO DO SO MAY CONSTITUTE GROUNDS FOR REJECTION.**